

Hydrological modelling dataset

Report 1: Infrastructure and hydro constraint attributes

Information paper

16 November 2015

Prepared by: Matthew Keir

Version control

Version	Date amended	Comments
1.0	16 November 2015	Draft report for review
1.1	8 December 2015	Final report

Preface

A large proportion of New Zealand's electricity needs are met by generation from hydro power. Information about the distribution of inflows and the capability of the various hydro systems is necessary to ensure a reliable, competitive and efficient market and electricity system.

The hydrological modelling dataset (HMD) contains hydrological information made available by the Electricity Authority. The dataset was known as the SPECTRA update until 2010. In 2015 the dataset was revised to become the HMD; a comprehensive dataset that can be relied upon by modellers and analysts to test scenarios, provide commentary and inform decisions.

The HMD is comprised of data provided by hydro generators and supplemented with some from other sources. These parties are acknowledged for their contribution and for making this data available.

The HMD consists of three main components:

- Infrastructure and hydrological constraint attributes
 This dataset records standing information about the capability of the main hydro schemes.
- 2. Flows

A time series dataset which records inflows for reservoirs and flows at various existing or potential hydro generating sites.

3. Storage and spill

A time series dataset which records storage for the main hydro schemes.

This information paper describes the first component of the HMD, the infrastructure and hydro constraints.

Contents

Pre	eface	ii
1	Infrastructure and hydro constraint attributes	1
2	Infrastructure attributes	1
3	Hydrological constraints Storage constraints Flow constraints	1 1 2
4	Summary of infrastructure and hydro constraint fields	2
5	Ranking method	5
6	Maintaining this dataset	6

1 Infrastructure and hydro constraint attributes

- 1.1 Infrastructure and hydrological constraints together define the capability of hydro generating schemes to store energy and produce electricity. This dataset records material attributes of generating plant and consents that govern storage volumes and flows associated with the 10 largest reservoirs from 1980 onwards.
- 1.2 The information has been collected from plant owners. It is needed to accurately derive the specific energy (in terms of electricity potential) of water in each reservoir and energy storage in GWh.
- 1.3 The dataset tracks changes in these attributes through time, allowing a view of capability and hydrological constraints which impact plant operation. Understanding historical capability is useful especially when undertaking analysis based on historical outcomes.

2 Infrastructure attributes

- 2.1 Infrastructure attributes are those defined primarily by the engineering aspects of the hydro generating station. The dataset captures both the capacity of the station and a plant factor that defines the relationship between flow and energy production. Table 1 describes the fields in the dataset.
- 2.2 Any infrastructure changes that alter either the plant factor or the capacity should be captured by the owner or station operator and passed on to either the system operator or the Electricity Authority (Authority). Examples could be re-runnering the hydro units, extending the capacity of the units by rewinding the generators, or even changing the operating regime of the reservoir to increase the average head during operation of the station.
- 2.3 Nominally, plant factors recorded represent an average factor over the last three years, unless an obvious intervention to the plant has taken place.

3 Hydrological constraints

3.1 Hydrological constraints apply only to **reservoir** or **hydro arc** plant types, and place restrictions on storage or flows. The list of hydro arcs is not exhaustive. Additionally, hydro nodes or junctions are not captured in the dataset. Modellers will have to take some additional details into account in their models.

Storage constraints

- 3.2 Reservoirs generally have standard operating ranges defined by consents. In some cases these vary by month or season. In addition, reservoirs can have contingent storage that becomes available when certain conditions are met. This additional storage has a material impact on the system, participant behaviours, and understanding risk and monitoring security of supply.
- 3.3 Some controls or restrictions on reservoirs can be complex and this dataset does not attempt to capture all these nuances especially around flood control or management.
- 3.4 There are four types of storage that are represented in this dataset:
 - (a) Active storage

- (i) Operational storage able to be used in the normal operation of the system by the scheme or plant operator. This storage may have seasonal consents, increasing the active storage at certain times of the year.
- (b) Consented contingent storage
 - Storage or a volume of water which becomes available to the generator (at the bottom of the active storage range) when certain conditions are met.
 Consented contingent storage and its associated conditions are defined in a consent or similar document.
- (c) Available contingent storage
 - (i) Recognises that although an operator may have consent to use storage, there may be other engineering-based or practical limitations that constrain the use of the storage, even when the consent conditions would allow an operator to use more. In terms of security of supply, this is the best measure of additional storage that will practicably become available.
- (d) Active contingent storage
 - (i) Tracks when consent conditions are met to trigger the use of the available contingent storage. The volume and dates are adjusted accordingly. Active contingent storage will normally be recorded as zero.

Flow constraints

3.5 Hydro systems can be complex and there are often multiple paths that water can take in a scheme. We've called these paths **hydro arcs**. Each of these hydro arcs can have a constraint that limits the operation of the hydro scheme in some way. This dataset captures the material restrictions to flow within the schemes enabling modellers to better approximate the true capability of the system.

4 Summary of infrastructure and hydro constraint fields

4.1 Table 1 records a summary and description of the fields in the dataset.

Table 1: Infrastructure and hydro constraint attributes

Field name	Format	Description
Plant group	text	Describes the hydro scheme that the plant is part of.
Island	2 char code	North Island (NI) or South Island (SI).
Site	3 char code	Provides a site code that links the individual station or asset to the wholesale market data. Some new codes have been introduced for hydrological sites that are not used within the market systems such as pricing or reconciliation.
Plant group rank	numeric	Rank applies a relative order for each asset or feature in the group or scheme. NZ hydro chains are linear (for generation) so this simple linear ranking methodology holds true. We use the first digit to rank reservoirs by the specific energy of the water within them - plant group

Field name	Format	Description
		rank 1 has the highest energy per cubic meter of water within the scheme. Reservoirs of equal rank are in the same stage in the hydro scheme. The first decimal value ranks hydro generating stations fed directly from the reservoir (without going through
		another reservoir). The second decimal value records hydro arcs or flow paths in their relative order from the reservoir. In all cases, equal ranking indicates parallel hydro arcs, hydro plant or reservoirs where storage has equivalent specific energy to the scheme. Sequential ranking indicates series flow. For example: 1.01 and 1.11 would be parallel hydro arcs from the first reservoir in the scheme. 1.01 refers to flow leaving the reservoir without going through a generator. 1.11 refers to the flow through the generating station. We do not record information for all flow arcs in the hydro scheme - only those that have material impact on the operation of the scheme. See the schematic in Figure 1.
Plant type	text	Plant types are: Reservoir Hydro Hydro arc
Sub type	text	Further breakdown of plant type. Reservoirs are either: Controlled Run of river. Hydro plant is recorded as hydro and not broken down into the various types of turbine technology (Francis or Kaplan etc.). Hydro arcs are one of: River Canal Station flow Spill flow.
Description	text	A description of the reservoir, hydro plant or hydro arc.
Attribute	text	 Reservoir plant types have attributes of: Active storage (million cubic meters or Mm3) Consented contingent storage(Mm3) Available contingent storage (Mm3)

Field name	Format	Description
		 Active contingent storage (Mm3) See section 3.4for a description of these types. Hydro plant has attributes of: Plant factor - nominally a three year average (cumecs/MW) Generating capacity (MW) Hydro arc plant types have attributes of: Max flow (cumecs)¹ Min flow (cumecs) Min monthly volume (Mm3) In the case of spill flow (a type of hydro arc), we identify the specific mechanism where it is known (e.g. max siphon flow).
Value	numeric	Records the numeric value or quantity for the attribute. Null should be read as there is no limit for this attribute. A null value does not mean that there is not another constraint restricting the attribute value.
Unit	text	The unit for the numeric value of the related attribute.
Start date	yyyy-mm-dd	Date in ISO format for when an attribute, value, schedule, source or consent begins to apply. For example, when infrastructure was modified or upgraded, a consent was renewed or amended, or available contingent storage is triggered (i.e. becomes active contingent storage).
End date	yyyy-mm-dd	Date in ISO format for when an attribute, value, schedule, source or consent ceases to apply.
Schedule	cron expression	Schedules apply only to hydrological constraints; either reservoir storage volumes (with a seasonal consent) or flow in hydro arcs. They make use of standard cron style expressions. Cron expressions are made of up to six fields that combine to represent a set of time spans. • Minute (0-59) • Hour (0-23) • Day of month (1-31) • Month (1-12) • Day of the week (0-6, where Sunday=0) • Year (0001-9999) Each field can include either; (a) an asterisk that covers the full allowable range, (b) an individual value, (c) a

_

¹ A cumec is a flow rate measures as a cubic meter per second.

Field name	Format	Description
		range of values, or (d) a list of both values and/or ranges. Fields are separated by spaces, lists by commas, and ranges are denoted by a hyphen. For example, a schedule that applies to office hours over summer (ie Mon-Fri, 9am-5pm, Oct-Mar), would appear as: * 9-17 * 1-3,10-12 1-5 * For more information see: https://en.wikipedia.org/wiki/Cron#CRON_expression
Source	text	The entity that provided the information.
Consent	alphanumeric	The relevant consent or document number.
Notes	text	Additional notes describing relevant contextual information. For example lake levels (that define the volume), a trigger condition for contingent storage, or a consenting body for a hydro constraint.

5 Ranking method

5.1 Reservoirs, hydro plant and hydro arcs in each hydro system are ranked; providing information on their relationship and dependence on each other in a simple numeric format. However, this information does not provide complete information on all nodes (start and end points) or hydro arcs. Users of the dataset will need additional information or knowledge to fully develop accurate flow system models. Figure 1 illustrates the linear ranking method adopted in the dataset.

[Rank] Plant type (sub type) X.YZ - Attribute Reservoir Hydro arc rank from rank in reservoir/hydro Hydro plant rank on reservoir Reservoir - (controlled or run of river) [1] - Active storage - Consented contingent storage - Available contingent storage - Active contingent storage - Specific energy (derived) [1.<u>1</u>] Hydro (hydro) Energy storage capacity (derived) - Average efficiency - Max generation [1.11] Hydro arc (station flow) [1.01] Hydro arc (spill) - Max flow Flow leaving the - Max spill flow reservoir that is not [1.01] Hydro arc (spill) used for generation - Max sluice flow at this point in the scheme [1.0<u>1</u>] Hydro arc (spill) - Max siphon flow Ranking of hydro arcs follows the [1.1<u>2</u>] Hydro arc (river) plant ranking (if one exists) even - Min flow if spill flow joins with generation flows. [1.1<u>2</u>] Hydro arc (canal) - Max flow [1.02] Hydro arc (canal) - Max flow [1.1<u>3</u>] Hydro arc (spill) - Max spill flow [1.13] Hydro arc (canal) - Max flow

Figure 1: Ranking within hydro schemes

6 Maintaining this dataset

6.1 The infrastructure and hydrological constraints dataset will be maintained as changes occur. If the infrastructure capability or consent conditions change, please let either the Authority know by contacting emi@ea.govt.nz, or the system operator through their consultations or discussions on security of supply.